

Attn: All Prospective Bidders

September 23, 2024  
190093201

**Re: Town of Brookfield, Connecticut  
Water Pollution Control Authority  
Phase II - 133 Pump Station  
RFP Number: 2024-02  
Addendum No. 2**

Dear Bidder:

You are hereby notified of Addendum No.2 to the Bid Package, dated August 28<sup>th</sup>, 2024, for the above-referenced project. Please note that you are required to acknowledge receipt of this Addendum within the Proposal (page P-4) and submit it with your bid package. Failure to do so may cause rejection of your bid.

A pre-bid meeting was held on September 17, 2024. The following are questions from the meeting and responses. Additional questions have been answered as part of Addendum 1.

1. Will there be a new transformer, or will the location of the previous transformer remain?

**Response: There will be a new transformer. It will be installed along the same wall as the existing transformer. See the revised electrical power plan, Drawing E-101 for the revised proposed transformer location.**

2. Since the generator has previously been removed from inside the pump house, and relocated out the pump house, will the housekeeping pad, used for the old generator location inside the pump house, be removed?

**Response: The housekeeping pad located inside the pump house shall be removed. The electrical demolition plan and single line plan, Drawing ED-101 has been revised to reflect this change.**

The following additional change has been made to the electrical demolition plan and single line plan, Drawing ED-101:

1. The existing water tank inside the pump house will be removed by the BWPCA for the duration of construction. The BWPCA will relocate the water tank after construction is completed.

END OF ADDENDUM NO. 2

\\Langan.com\data\WPWData2\190093201\Project Data\Office Data\2024-09-11 Bid Package Revised (REBID) rev\2024-09-23 Addendum 2.docx